

Castell Interlocks Inc. 150 North Michigan Avenue Suite 800, Chicago IL 60601

t: 312-360-1516 f: 312-2685174 ussales@castell.com

www.castell.com

Salvo Maintenance

Under normal operating conditions very little maintenance is required. If used in dusty conditions blowing out with compressed air will prevent a build up of sediment in the locks.

The use of **Graphite Powder** is recommended if necessary.

<u>Under no circumstances</u>, however, should the locks be oiled or greased as this causes the locks to clog and malfunction. All locking systems should be checked regularly for correct operation, security of fixings and condition of keys etc. The entrapment of all keys that should be trapped must be checked under operating conditions, as should the ease of removal of liberated keys.

In the event of malfunction, evident wear or damage, parts should be replaced or returned to Castell for repair if appropriate. Users of interlock systems have a duty to ensure that the systems are not only correctly installed but are maintained in a satisfactory condition. However, we are here to help.

Castell Interlocks Inc.

